

**CENTRAL MAINE POWER COMPANY
RESPONSE TO EXAMINER'S DATA REQUEST NO. 4
DOCKET No. 2008-255**

October 17, 2008

EX-04-04

- Q.** (Volume VII, Page 4 of 573) Please provide a detailed list of the recent changes that were made in the rating methodology for line ratings established by ISO-NE. Please also identify in detail what level of the Maine Transmission System is required under ISO-NE PP-7 to adhere to this new rating methodology.
- A.** ISO New England Planning Procedure 7 was adopted by NEPOOL and ISO in spring 2007, and is attached to the data response to EX-02-07. Per Section 1.0 of PP-7, it applies to all facilities 69 kV and above.

Response Prepared & Submitted By:

David Conroy
Manager of System Planning
Central Maine Power