

**CENTRAL MAINE POWER COMPANY  
RESPONSE TO EXAMINER'S DATA REQUEST NO. 9  
DOCKET No. 2008-255**

May 28, 2009

**EX-09-02**

- Q.** Reference page 2, chart. In addition to the actual peak loads supplied, please supply 50/50 and 90/10 weather corrected peaks for the same time period on the same chart.
- A.** The requested data is not available. The chart on page 2 references actual summer peak load. The table below provides weather normalized vs. actual summer peak loads, 2000-2008. CMP does not weather correct peaks to 90/10 weather conditions.

**Summer Peaks (MW) 2000-2008**

	<u>Actual</u>	<u>W/N</u>
2000	1,476.4	1,599.0
2001	1,595.9	1,451.6
2002	1,540.7	1,439.5
2003	1,524.3	1,488.5
2004	1,518.9	1,617.0
2005	1,682.5	1,575.6
2006	1,680.6	1,671.6
2007	1,610.7	1,585.6
2008	1,563.1	1,694.0

**Response Prepared By:**

Kirk P. Pelletier  
Lead Analyst  
Central Maine Power Company

**Response Submitted By:**

John P. Davulis  
Senior Project Manager  
GDS Associates, Inc.