

**CENTRAL MAINE POWER COMPANY  
RESPONSE TO ORAL DATA REQUEST NO. 3  
DOCKET No. 2008-255**

December 11, 2008

**ODR-03-27**

- Q.** For the past ten years, provide the system contribution to SAIFI and CAIDI by three categories of voltage: 115kV and above, 34.5 kV, and everything below 34.5kV. (Or by two voltage categories: 115, kV and above, and everything below 115kV.) Also provide the cause code for any outage in that time period.
- A.** CMP calculates CAIDI and SAIFI metrics at the distribution level and cannot readily determine the portion of these metrics attributable to transmission outages. However, in order to be responsive to this request, CMP is providing outage data for its transmission system. In addition, outages by cause code (one cause code being transmission outages) for 1995 through 2000 are provided in Attachment #2 and outages by cause code for 2001 through 2007 are included as Attachment #3

**Response Prepared By:**

Michael L. Watson  
Director Maintenance Engineering  
Central Maine Power Company

**Response Submitted By:**

Paul A. Dumais  
Director of Regulatory Services  
Central Maine Power Company

**Attachments:**

1. Transmission outage data
2. Outage by cause code for 1995 through 2000
3. Outage by cause code for 2001 through 2007