

STATE OF MAINE PUBLIC UTILITIES COMMISSION

DOCKET NO. 2008-255

**CENTRAL MAINE POWER COMPANY
Request for Certificate of Public Convenience
and Necessity for the Maine Power Reliability Program
Consisting of the Construction of Approximately
350 miles of 345 kV and 115 kV Transmission Lines ("MPRP")**



Central Maine Power
Your Electricity Delivery Company

VOLUME VI

**REBUTTAL TESTIMONY
of
GEORGE C. LOEHR**

**TRANSMISSION PLANNING OVERVIEW
MAINE POWER RELIABILITY PROGRAM**

December 4, 2009

**Attorneys for Central Maine Power Company
Jared S. des Rosiers
Thomas L. Welch
PIERCE ATWOOD LLP
One Monument Square
Portland, ME 04101**

**REBUTTAL TESTIMONY OF
GEORGE C. LOEHR**

**Transmission Planning Overview
Docket No. 2008-255**

1 **OVERVIEW**

2 Most of the opposition to the MPRP seems to center on the interpretation of
3 “stress” – what it means to stress the power system prior to the application of
4 contingencies in a planning or reliability assessment study. As I describe below, the
5 testing done for MPRP was proper, and the criticism of the manner in which CMP and
6 ISO-NE applied the NERC and NPCC standards is unwarranted.

7 One can visualize the process of testing the system for transmission system
8 planning by dividing it into two areas: the assumptions as to how the base system should
9 be modeled; and the contingencies which the system must survive without overloads, low
10 voltages, instability, system separations, or blackouts. Application of contingencies is
11 fairly straightforward; NERC, NPCC and ISO-NE are all quite specific and consistent as
12 to the contingencies which must be applied to the system – there is very little room for
13 interpretation. On the other hand, the planning entity is given significant leeway as to
14 base case assumptions.

15 As pointed out in my prior testimony, filed on February 23, 2009, NERC
16 standards were made mandatory by FERC’s selection of NERC as the ERO, as per EPAct
17 2005. NPCC and ISO-NE criteria may be more stringent or more specific, but they must
18 conform to NERC’s standards as a minimum. Further, NPCC’s “Basic Criteria for
19 Design and Operation of Interconnected Power Systems” (Document A-2) are effectively
20 mandatory as well. The original NPCC Memorandum of Agreement provided that any

1 signatory unable or unwilling to comply with any of the requirements was legally obliged
2 to notify the other members, through the NPCC committee structure.¹

3 NERC uses the phrase “critical system conditions” in describing the ground rules
4 for base case assumptions: “The selection of ‘critical system conditions’ and its
5 associated generation dispatch falls within the purview of [the Planning Coordinator’s]
6 ‘methodology.’ ” NERC also directs that “a Planning Coordinator would formulate
7 critical system conditions that may involve a range of critical generator unit outages as
8 part of the possible generator dispatch scenarios.” (NERC TPL-002a p. 7 and TPL-003a
9 p. 7 – March 13, 2008 interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.2)
10 NPCC and ISO-NE use the word “stress.” In my opinion, MPRP planners interpreted the
11 concept of “critical system conditions” or “stress” in a manner appropriate to the letter
12 and spirit of the NERC, NPCC and ISO-NE requirements. They also acted in a manner
13 consistent with long-term industry practice in North America. In these respects, I
14 strongly disagree with the Bench Analysis. I particularly take issue with the argument
15 that MPRP made assumptions more conservative (i.e., more likely to establish a need for
16 new transmission) than other entities – specifically, PJM and NYISO.

17

18 **THE CONCEPT OF “REASONABLE STRESS”**

19 The NERC requirement concerning “critical system conditions” and the NPCC
20 and ISO-NE requirements concerning “stress” must be taken seriously. They do not refer
21 to something that happens all the time, or even frequently. The purpose of these

¹ In addition, NPCC (along with the other reliability councils) now has the option of submitting its more stringent or more specific reliability criteria to NERC as “Regional Differences.” After passing through the normal NERC review and approval process, they would carry the same mandatory obligations, and NERC/FERC enforcement powers, as other more general NERC standards.

1 provisions is to simulate or replicate the processes and procedures used in the actual
2 operation of the system – recognizing that stressed conditions, while not the norm, do
3 occur from time to time, and that the system must be able to provide uninterrupted
4 service when they do.

5 This might be likened to designing a bridge or skyscraper to withstand hurricane-
6 force winds, even though, in the words of Henry Higgins, hurricanes hardly happen.
7 Flood control systems provide another useful analogy. We expect them to withstand, say,
8 a “hundred year flood” – a flood condition that has only a 1% chance of occurring in any
9 given year.

10 Finally, we can learn a lot from general electric industry practice. Over the past
11 half-century, these stressed conditions have become the common assumptions in virtually
12 all planning and reliability assessment studies. Examples include such efforts as the Post-
13 1965 Blackout Studies, the NERC Transregional Transfer Study of the 1970s, the MEN
14 and VEM Future System Studies done throughout the '70s, '80s, and into the '90s, and
15 the NPCC Triennial Assessments and Overall Assessments conducted over the last 30
16 years. MPRP simulated stresses to the system of the same level of severity as these
17 historical studies.

18 Similarly, the Bench Analysis statement about “over design” of the system such
19 that “there will be little need for operators to react in real time to actual system stresses”
20 (pp. 23-24) suggests a lack of understanding of the system operators’ role when a
21 contingency occurs. In actual operations following a disturbance, system modifications
22 are *not* made to reduce overloads or otherwise correct for adverse effects of the
23 contingency, but to set up the system for the next contingency that could happen.

1 Otherwise, the system might not be able to survive a new contingency. The system must
2 always be operated such that any contingency can be survived without overloads, low
3 voltages, or other unacceptable conditions, as specified in national, regional, and local
4 standards and criteria. In its “normal” state, the system may never be operated such that a
5 first contingency would result in violations, and operator action would be required to
6 correct them.

7

8 **GENERATION DISPATCH & BASE TRANSFERS**

9 The Bench Analysis states that the MPRP assumptions regarding generation
10 dispatch and transfers are more stringent than those followed by the NYISO or PJM.
11 From my work with both the New York and PJM systems, I can state categorically that
12 this is not the case. First of all, with regard to an appropriate dispatch for transmission
13 and reliability assessment studies, it isn't really valid to compare Maine with New York
14 State or PJM. The Maine system has a peak load of approximately 2,000MW. The
15 NYISO has a peak of about 34,000MW – seventeen (17) times higher. PJM's peak load
16 is 136,000MW – a breathtaking sixty-eight (68) times higher. Even the so-called
17 “classic” PJM (the PJM system as it was prior to its westward expansion following the
18 2003 blackout) is roughly thirty (30) times larger than Maine's. Dispatch strategies
19 appropriate with these very large systems generally will not work with much smaller
20 systems, like that studied by MPRP.

21 The probabilistic Loss of Load Expectation (LOLE) technique, as used by NYISO
22 and PJM in dispatching generation for transmission assessments, would not be a good
23 approach for Maine. It has been my experience that, when probabilistic techniques like

1 the LOLE are applied to small systems with a relatively limited number of generators,
2 results tend to be anomalous. Whenever one deals with small sample sizes, historical
3 data with regard to any one element will have a disproportionate impact on the results.

4 For smaller geoelectric areas, evaluating the outage of discreet generators instead
5 is more appropriate, and “two units out” is widely used in the industry. In New York,
6 when transmission owners actually conduct transmission planning studies for areas
7 smaller than the entire ISO, the outage of two large units, or in some cases a single
8 multiple-unit plant, is the norm. PJM uses a more complex method, which will be
9 discussed later in my testimony. Even when a discrete unit approach is used, several
10 categories of generators should be removed first. These would include units likely to
11 retire, units that run only a small number of hours a year, and older units – say more than
12 40 years of age – unless there are some mitigating circumstances, like a commitment to
13 or completed refurbishment. Further, the co-dependency of certain types of generators
14 should be recognized. Many combined cycle units are designed such that one element
15 cannot operate independent of others. Also, the consequences of a loss-of-gas
16 contingency should be considered if the same gas supply is used by more than one
17 generating unit.

18 It is prudent to study the effects of contingencies for a number of dispatch
19 scenarios. This is, in fact, called for by NERC: “[A] variety of possible dispatches
20 should be included in planning analyses.” NERC also states that the “selection of
21 ‘critical system conditions’ and its associated generation dispatch falls within the purview
22 of [the Planning Coordinator’s] ‘methodology.’ ” (ISO-NE is the NERC-approved
23 “Planning Coordinator” for New England.) Finally, NERC directs that “a Planning

1 Coordinator would formulate critical system conditions that may involve a range of
2 critical generator unit outages as part of the possible generator dispatch scenarios.”
3 (February 8, 2005 NERC interpretation of Standards TPL-002 and -003.)

4 Incidentally, a generating unit assumed to be initially out of service is not
5 considered a “contingency.” A contingency is a sudden occurrence, rarely anticipated,
6 which occurs without warning – like the sudden tripping of a generator, or a fault and
7 loss of a major transmission line or transformer. NPCC defines a contingency as “[a]n
8 event, usually involving the loss of one or more elements, which affects the power system
9 at least momentarily.” (NPCC Document A-7, *Glossary of Terms*, p. 5.)

10 While I have not conducted an independent analysis of each generating unit in the
11 Maine system, it is my conclusion that the CMP and ISO-NE planners have been both
12 careful and prudent in how they decided on the several generation scenarios used in
13 MPRP.

14 With respect to transfer levels, the Bench Analysis criticizes the MPRP studies for
15 using base inter- and intra-area power transfers which are, in Staff’s opinion,
16 unreasonably high. I do not agree. First of all, it is not the intent of planning studies to
17 represent *typical* or *normal* conditions. The purpose is to test the system under *stressed*
18 conditions. More important, it has been a long-term industry practice to represent inter-
19 and intra-area power transfers at or close to the established transmission transfer
20 capabilities. Thus ISO New England Planning Procedure PP5-3 requires that “intra-area
21 transfers will be simulated at or near their established limits (in the direction to produce
22 ‘worst cases’ results).” (Section 3.3.1.1 g.)

1 PP5-3 is following an established industry protocol that no development on the
2 system, whether it is a new generator, new transmission line or transformer, or simply
3 load growth, should result in any deterioration in the bulk power system's ability to
4 transfer power within or between areas or regions. An example of this principle was the
5 so-called "Phase 2" HVDC project between Radisson (James Bay) and Sandy Pond
6 (outside Boston). When this project was first announced in the 1980s, a special MAAC-
7 ECAR-NPCC (MEN) study was initiated to see if it would have adverse effects on other
8 systems. It was discovered that contingency loss of the HVDC line, while operating at its
9 planned capacity of 2,000MW, could result in the deterioration of transmission transfer
10 capabilities in PJM and, to a somewhat lesser extent, in New York. As a result, Hydro-
11 Quebec and NEPOOL agreed not only to change certain arrangements of facilities, but to
12 limit flow on the tie such that its contingency loss would never be more limiting on
13 transfer capabilities in PJM or New York than the worst single contingencies that could
14 occur in either of those systems. This agreement is still in effect today. It *is* acceptable,
15 however, to assume that transfers could be modified as "manual system adjustments"
16 between the two contingencies of an N-1-1 test -- if in fact that could be accomplished in
17 the time allowed. Of course, any adjustments to power transfers must be coordinated
18 through the ISO and, where appropriate, with other entities.

19 At the November 17, 2009 technical conference, Staff's consultant made a
20 distinction between what he characterized as "economic transfer limits" and "reliability
21 transfer limits." He maintained the former should be represented in the base cases, not
22 the latter. The fact is that *none of the standards (NERC, NPCC, ISO-NE) make such a*
23 distinction. There is absolutely no basis in the national, regional or ISO-NE standards or

1 criteria for such a distinction. These are all reliability standards, and apply whether
2 transfers are for economic, capacity emergency, or any other purpose. They should be
3 modeled at their established limits.

4 Staff's consultant also argued that MPRP did not make adjustments following the
5 first contingency in N-1-1 studies. This is incorrect. He also said that, after the first
6 contingency, the system is in an emergency situation, and emergency thermal and voltage
7 ratings should be used. Nothing in NERC, NPCC, or ISO-NE standards states that the
8 post-first-contingency system should be regarded as an emergency condition, calling for
9 the use of emergency ratings. Further, neither the NYISO nor PJM assume that the post-
10 first-contingency system is in an emergency condition.²

11 Staff makes a profound error in its response to CMP-08-84 when it says that
12 "reliability standards do not require construction of facilities if the operators can resolve
13 the violation." NERC and NPCC standards clearly require that the system be planned to
14 ensure that, following the first contingency, there are *no* violations of criteria. The
15 operator actions following a first contingency (n-1) are designed to position the system so
16 that, in the event of a second contingency (n-1-1), the system can again survive with *no*
17 violations. The reason for this is obvious to good planners: if, for example, the violation
18 that occurs following the n-1 event is a voltage collapse, it is hard to imagine what
19 operator action could make a difference; if the violation is system instability, which
20 usually occurs in less than ten seconds, there wouldn't even be time for operator action.

21

² This error is repeated in Staff Response to CMP-08-83.

1 **MORE STRINGENT NERC STANDARDS ARE COMING**

2 It is quite likely that NERC planning requirements will soon become significantly
3 more stringent. Failure to comply, of course, will be a violation under federal law. One
4 possible change has to do with the definition of Bulk Electric System – those facilities to
5 which the NERC standards are applicable. As I said in response to EX-11-17:

6
7 “At present, transmission components applicable to NERC, NPCC and other
8 reliability standards and criteria are specified by the NPCC definition of Bulk
9 Power System (see NPCC Document A-7, *NPCC Glossary of Terms*): ‘Bulk
10 power system – The interconnected electrical systems within northeastern North
11 America comprised of system elements on which faults or disturbances can have a
12 significant adverse impact outside of the local area.’ This has been referred to as
13 a ‘performance based’ standard. However, FERC is attempting to require
14 application of NERC standards to all transmission facilities operated at 100kV or
15 higher, with the exception of radial lines; this has been referred to as a ‘bright
16 line’ standard. NPCC and its members are defending a ‘performance based’
17 approach. The final outcome of this FERC initiative is uncertain, and its impact
18 on NPCC and its members is still unclear.”
19

20 If ordered by FERC, as now appears likely, a 100 kV bright line for the definition
21 of the Bulk Electric System could require application of N-1-1 contingencies to the entire
22 115 kV system in Maine. It should be noted that the MPRP studies did *not* apply N-1-1
23 contingencies to the 115 kV system, as alleged by Staff’s consultant at the November 17,
24 2009 technical conference.

25 The other change on the horizon is a revision to the current NERC Standards
26 TPL-001-0, TPL-002-0a, TPL-003-0a, and TPL-004-0. Its designation is TPL-001-1,
27 and, if approved, it will replace the present standards. It has already been through several
28 rounds of posting and comments as per the NERC process for new or revised standards,
29 and could be balloted before the end of 2009. Approval by the NERC Board and FERC

1 is anticipated early in 2010. It is considerably more stringent than the current planning
2 standards, and will possibly require additional transmission reinforcements, beyond those
3 recommended in MPRP. For example, in TPL-001-1, N-1-1 contingencies which begin
4 with the loss of a generating unit must be applied to both EHV (above 300kV) and HV
5 (below 300kV) facilities without interruption of firm transmission service or non-
6 consequential load loss.

8 **LOAD LEVEL**

9 The Bench Analysis argues that the current recession has reduced load growth,
10 and made the MPRP reinforcements less important. Also, the use of 90/10 loads was
11 criticized. I make the following observations:

12 • Historically, load has grown at a significantly higher rate than in recent years,
13 even prior to the recession. According to actual U.S. Energy Information Administration
14 statistics, retail sales of electricity in 1970 were *five times higher* than in 1950 – a
15 compound annual growth rate in excess of 7%. It doubled again between 1970 and 1990
16 – approximately a 3% growth rate – despite oil embargoes, hyper-inflation, recession,
17 and conservation efforts.³

18 • The Bench Analysis argues that MPRP’s use of 90/10 peak loads is uncommon
19 in the industry. This is not true. Most of the systems with which I am familiar now use
20 90/10 in transmission planning studies as one of the ways to satisfy the NERC “critical
21 system conditions” requirement. As I said in my answer to OPA Question #5 (a. through
22 f.): “[M]any systems presently use the 90/10 load forecast as one of the ways to stress

³ See attached Chart showing peak load level increases in the U.S. areas of NPCC.

1 the system in reliability studies – e.g., ISO-NE, PJM, MISO, and some of the systems
2 located in the SERC and WECC regional reliability councils. Others are considering
3 changing from 50/50 to 90/10 – e.g., the New York ISO.”

4 The Bench Analysis states (p. 14) that “PJM transmission reliability design
5 criteria use a 50/50 load forecast.” In fact, PJM uses 90/10 within the study area. This
6 was the load level used in determining the transmission reinforcements needed to achieve
7 the Capacity Emergency Transfer Objectives (CETOs) in the recent TrAIL,⁴ PATH,⁵ and
8 other PJM planning efforts. “This test examines the deliverability under the stressed
9 conditions of a 90/10 summer load forecast.” (PJM Manual 14B, “PJM Regional
10 Transmission Planning Process,” Load Deliverability Analysis section, p. 16.) I will
11 discuss PJM more fully later on.

12 With particular regard to New England, recent transmission reliability studies,
13 including Vermont, Connecticut, and the Springfield area of Massachusetts, used 90/10
14 peak loads. The NYISO, ISO-NE, and PJM resource adequacy, Loss of Load
15 Expectation (LOLE) studies all include load forecast uncertainty, so the probability of
16 actual load exceeding forecast (e.g. 90/10) is incorporated. In late 2002, the NEPOOL
17 Reliability Committee recommended that 90/10 forecasts be used in all planning
18 assessments. This recommendation was adopted by the Transmission Task Force in early
19 2003.

20 • In any event, the MPRP is needed now, even at current load levels. The Maine
21 system currently relies on a number of Special Protection Systems (SPSs) in order to
22 avoid violations of NERC and NPCC standards and criteria. These devices, which are

⁴ Trans Allegheny Line; see <http://www.pjm.com/planning/rtep-upgrades-status/backbone-status/trail.aspx>

⁵ Potomac-Appalachian Transmission Highline; see <http://www.pjm.com/planning/rtep-upgrades-status/backbone-status/path.aspx>

1 permissible only for short periods, have been on the Maine system for several decades.
2 They are a significant liability to reliable system operation, even when they operate
3 correctly. On July 2, 2009, the Maine Yankee-Maxcys 345kV line (circuit 392) tripped
4 during an electrical storm. Operation of the associated SPS caused the separation of the
5 Bangor, northern Maine, New Brunswick, Nova Scotia and PEI systems from the Eastern
6 Interconnection – a major system separation. While SPSs are permitted by the various
7 standards and criteria, it was always understood that they would be regarded only as a last
8 resort, a temporary expedient. NPCC’s “Basic Criteria” states:

9

10 “A[n] SPS may be used to provide protection for infrequent contingencies, or for
11 temporary conditions that may exist such as project delays, unusual combinations
12 of system demand and equipment outages or availability, or specific equipment
13 maintenance outages.”
14

15 As I said in my prior testimony, “SPSs should be considered only as a last resort,
16 not as a normal planning tool. They introduce many uncertainties into power system
17 performance following major contingencies. Among these are unintended consequences
18 and unpredictable mutual effects. Furthermore, these problems increase exponentially as
19 SPSs proliferate, and their complexity grows. Not every disturbance to the power system
20 can be anticipated. Even if every possible disturbance could be predicted, to test them all
21 against each of the almost infinite number of configurations in which the system might be
22 found would literally be impossible.”

23 Finally, on the night of the August 14, 2003 Midwest/Northeast blackout,
24 inadvertent operation of an SPS associated with the (then) single tie line between
25 northern Maine and New Brunswick occurred, aggravating the response of the system.

1

2 **ERRORS IN BENCH ANALYSIS CONCERNING NEIGHBORING ISOs**

3 **PJM**

4 The Bench Analysis (p. 20) has misunderstood and misrepresented the approach
5 used by PJM for generation dispatch.⁶ For its transmission reliability assessment studies,
6 PJM divides its system into geo-electric areas called “Load Deliverability Areas,” or
7 LDAs. The most important of these from the point of view of transmission requirements
8 is the Mid-Atlantic LDA. It comprises the original or, as PJM calls it, the “classic” PJM
9 system – the PJM area as it existed prior to the addition of Dominion, APS, AEP, and
10 other western systems following the 2003 blackout. For each LDA, PJM does a Loss of
11 Load Expectation (LOLE) study to determine the import capability necessary to maintain
12 a “one day in 25 years” LOLE. (Note the use of one day in 25 years, not the usual one
13 day in 10.) The resultant value is called the Capacity Emergency Transfer Objective
14 (CETO) for that LDA.

15 In theory, the Capacity Emergency Transfer Objective (CETO) is the amount of
16 import capability which the LDA geo-electric area would require to allow it to satisfy the
17 chosen loss of load expectation of one day in 25 years, given the LDA’s 90/10 loads and
18 the amount of generation it contains.

19 The CETO then becomes the basis for the transmission studies, using
20 conventional load flow techniques. A 90/10 load level is used for the LDA; 50/50 loads
21 are used external to the LDA. A single mean or median generation schedule is developed
22 for the LDA, using the same probabilistic statistics as in the LOLE study, to

⁶ Staff conceded in its response to CMP-08-42 that it had not assessed the impact of, for example, using PJM’s longer planning horizon.

1 accommodate an import equal to the CETO. A base case load flow is developed at that
2 import level, and examined as per NERC Planning Standard TPL-001-0. Then the
3 various contingency cases are run as per Standards TPL-002-0a and TPL-003-0a. If the
4 existing transmission system results in violations for any of these (A, B, and C), PJM
5 concludes that a transmission reinforcement is required.

6 PJM's "one day in 25 years" standard – used to come up with the CETO number
7 – is a much more conservative assumption than the one day in 10 years used by NPCC
8 generally (NE, NY, and the Canadian systems), and by ISO-NE in particular. PJM
9 admits that this is a conservative assumption – they defend it as part of the need to
10 "stress" the system. By comparison, one day in 25 years is a higher standard than that
11 used by either ISO-NE or the NYISO, each of which is only about half the size of the
12 Mid-Atlantic LDA.

13 ISO-NE and NYISO each use an adequacy criterion of one day in 10 years, yet
14 each is approximately one-fourth the size (in MWs) of the PJM system. Standardized to
15 the size of the PJM system, ISO-NE and NYISO at one day in 10 years would be
16 equivalent to *four* days in 10 years. If PJM used a criterion of one day in 10 years instead
17 of one day in 25 years for the Mid-Atlantic LDA, and put it on the same LOLE basis as
18 ISO-NE and NYISO, I believe that PJM could lower the current 8,000MW CETO for the
19 Mid-Atlantic LDA by approximately 3,000MW. Clearly, the PJM approach is far more
20 conservative than ISO-NE's, develops a higher target transfer capability, and results in
21 more transmission apparently being required.

22 Of course, this case is not about whether the PJM standards are appropriate. My
23 point is that, contrary to the assertion in the Bench Analysis, the PJM approach is

1 considerably more conservative and results in more “required” transmission than the
2 approach used in ISO-NE and by MPRP.

3 At the November 17, 2009 technical conference, Staff’s consultant maintained
4 that PJM does a better job of long range analysis since it looks 15 years out. This is
5 technically incorrect. PJM does report conclusions that far into the future, but all
6 “results” beyond the fifth year are extrapolated from the 5-year studies. In my opinion,
7 results based on extrapolated results are worth very little. In fact, they can lead to
8 distinctly incorrect conclusions since they cannot anticipate major changes in system
9 development.

10 At that same technical conference, a Staff member talked about “other
11 jurisdictions” that use less stringent criteria than ISO-NE – NYISO and especially PJM
12 were cited. Actually, as discussed below, NYISO standards are quite comparable to ISO-
13 NE’s – not surprising, since both follow the NPCC Basic Criteria (A-2). PJM, however,
14 uses criteria significantly more stringent than ISO-NE’s, as I described earlier in this
15 section.

16 The Staff member also said NYISO and PJM “left much less to planner
17 judgment.” This is totally incorrect. ISO-NE criteria go considerably further in
18 specifying what assumptions should be made than either NYISO or PJM. For example,
19 ISO-NE’s PP5-3 states that “intra-area transfers will be simulated at or near their
20 established limits (in the direction to produce ‘worst cases’ results).” (Section 3.3.1.1 g.)
21 Neither NYISO nor PJM criteria are that specific. Similarly, PP5-3 requires that
22 “[t]esting should not be restricted to only typical dispatch; rather the dispatch(es) should

1 be developed to reasonably test the proposed additions or changes.” (Section 3.3.1.1 f.)
2 Again, neither NYISO nor PJM criteria are that specific.⁷

3 Finally the Staff member said that she’d been told “by a PJM planner” that they
4 do not use generator outages in their base cases. While this may be literally correct, the
5 CETO methodology described above is far more conservative than the two-unit-out
6 approach used in MPRP. A requirement for 8,000MW of import capability into the so-
7 called Mid-Atlantic LDA, as described earlier, is far worse than the outage of two units!
8

9 NYISO

10 The New York ISO approach is based on an annual Comprehensive Reliability
11 Planning Process (CRPP). Its purpose is to assess and establish the reliability needs of
12 the New York system, and identify solutions to maintain reliability. The first step in the
13 CRPP is the Reliability Needs Assessment (RNA), which evaluates the adequacy and
14 security of the bulk power system over a 10 year study period. First, resource adequacy
15 needs are assessed using probabilistic techniques, based on the same 11-area approach
16 used in the annual New York State Reliability Council (NYSRC) Installed Capacity
17 Requirements study. Next, the NYISO requests and evaluates market-based and
18 regulated backstop and alternative solutions to the needs, and develops a Comprehensive
19 Reliability Plan (CRP). If the RNA identifies a reliability need, the NYISO designates
20 one or more Transmission Owners (TOs), which then are responsible for developing a
21 regulated backstop solution in case the market should fail to respond. The NYISO also
22 requests market-based and alternative regulated solutions. The proposed solutions could

⁷ Staff’s Response to CMP-08-77 shows that Staff continues to misunderstand or mischaracterize PJM and NYISO planning procedures.

1 be either resource or transmission additions, or a combination of both. But all proposed
2 solutions, whether resource or transmission, must satisfy the NYSRC reliability criteria.

3 The criteria used in the NYISO RNA studies, and any studies performed by TOs
4 or other market participants in New York, are essentially the same as those used in New
5 England. There is only one exception: the criteria used by Con Edison. But Staff gets
6 this wrong. The Bench Analysis states (p. 24): “In the Consolidated Edison system,
7 which covers the New York City area, it is Staff’s understanding that Con Ed designs the
8 138 kV system to an N-1 standard.” This is incorrect. In fact, Con Edison uses *second*
9 *contingency* (N-2) design for all of the 345kV system and for much of its 138kV system:

10

11 “Con Edison’s Transmission Load Areas are designed as follows: Those supplied
12 by the 345 kV transmission system are designed for second contingency; Specific
13 138 kV Transmission Load Areas are also designed for second contingency; and
14 The remaining 138 kV Transmission Load Areas are designed for single
15 contingency.”
16

<u>Transmission Load Area</u>	<u>Design Contingency</u>
New York City 345/138 kV	Second
West 49th Street 345 kV	Second
New York City 138 kV	Second
Astoria 138 kV	Second
East 13th Street 138 kV	Second
Astoria East/Corona 138 kV	Second
Astoria West/Queensbridge 138 kV	Second
Vernon 138 kV	Second

1

2 (Con Edison *Transmission Planning Criteria*, August 25, 2009, p. 5;
3 Attachment 1, "Transmission Load Areas," p. 10)

4

5 The chart above demonstrates that Con Ed uses N-2 for all 345kV. In addition,
6 Con Ed uses N-2 for all 138kV in Manhattan and much of the 138kV in Queens. As an
7 aside, it was precisely the use of n-2 criteria for 138kV transmission that allowed the
8 rapid restoration of power supply in Lower Manhattan following the September 11, 2001
9 terrorist attacks on the World Trade Center.

10 The Bench Analysis (p. 24) also draws an incorrect conclusion from the NYISO
11 Comprehensive Reliability Planning Process Manual. "In defining 'plausible' scenarios,
12 NYISO takes into account that 'too many scenarios will cause more confusion rather than
13 provide clarity for decision making.'" Staff seems to imply that the NYISO manual
14 prohibits a scenario approach, when *in its own words* the Bench Analysis acknowledges
15 that, "in the NYISO area, the planning manual uses a 'scenario' approach 'to model the
16 bulk power system where multiple and well reasoned future conditions are postulated.'" "
17 The last formulation is correct, and shows the consistency between the approach in
18 MPRP and the approach taken by the NYISO. There is a value in studying multiple
19 scenarios, since potential problems may not be identified if only one system
20 configuration is examined. In my opinion, their use in MPRP was appropriate.

21 In summary, although NYISO and PJM deal with generation dispatch and
22 stressing the system in somewhat different ways than ISO-NE or the MPRP, a careful and
23 thorough analysis demonstrates that NYISO's approach is about on a par with MPRP's,

1 while PJM's is considerably more stringent. In other words, if one were to use the
2 NYISO methodology in MPRP, the transmission needs would be about the same. Use of
3 PJM's approach, however, would lead to considerably more transmission.


4

5 **CONCLUSION**

6 Whatever decision is ultimately made, it should include consideration of the
7 consequences of being wrong. In other words, if the MPRP is built as proposed, but it
8 turns out it wasn't needed as early as envisaged, the only effect will be a more robust
9 system for a few years until it *is* needed. On the other hand, if it isn't built but it turns out
10 that it really *was* needed, Maine consumers will be faced with an unreliable electric
11 supply – which will adversely affect their personal lives as well as the state's economy. I
12 believe the prudent course of action for the State of Maine is to approve and build the
13 MPRP as proposed.

14

Ten year increases in peak load in NPCC. Each bar shows percentage increase for a ten year period beginning with 1986 to 1996.



Source: EIA 2008 Annual Review

Base year Load	39,026	42,651	45,245	45,031	44,116	46,594	43,658	46,706	47,581	47,705	45,094	49,269	49,566	Ave. of 13 10-year periods is 19.6%
10 Year Later Load	45,094	49,269	49,566	52,855	50,057	55,949	56,012	55,018	52,549	58,960	63,241	58,314	61,779	
% Change	15.5%	15.5%	9.6%	17.4%	13.5%	20.1%	28.3%	17.8%	10.4%	23.6%	40.2%	18.4%	24.6%	

Recessions

July 1990 - March 1991 Oil price shock and S&L Crisis
 March - November 2001 DotCom Bubble and 9/11 Attack
 December 2007 - Subprime meltdown